


# 8" WSP Pump Curve



Suction: 8"  
 Discharge: 8"  
 Impeller Diameter: 14.75"  
 Max. Solid Sphere: 3.00"

REPRIMING LIFTS	
RPM	FEET
650	9
750	12
850	15
950	17
1050	20
1150	21
1250	22
1350	23

Determine NPSHR prior to using repriming table. Do not use available suction lifts.

Clear Water Performance

$$BHP = \frac{GPM \times FT \times}{3960 \times Efficiency}$$

$$KW = \frac{M^3 / HR \times M}{367 \times Efficiency}$$

© Copyright All rights reserved **SPECIALTY PUMPS**

Certified tests are performed using Hydraulic Institute acceptance level B.

**APRIL 2006**

**RPM  
 VARIABLE**

**WSP8A**